

## Meftahul Zenan

**From:** Meftahul Zenan [mefta@cross-world.com]  
**Sent:** Wednesday, January 17, 2018 10:58 AM  
**To:** 'Maruf Ahmed'; 'iftekhar@cross-world.com'  
**Cc:** 'sultan@cross-world.com'; 'moshiur@cross-world.com'; 'haroon@cross-world.com'; 'zia@cross-world.com'  
**Subject:** RE: Absoulte wear ltd.

Dear Sir,

Reference of bellow mail, as mentioned project BBT Material shifted at site.

But we found that some mismatch (Fixing Bracket) in materials as bellow-

1. MK 40 nos fixing bracket has smaller then BBT outside body.
2. And TB 12 nos Fixing bracket has less where as TB 12 nos Joint unit has extra.

Now we need to replies from our ready stock.


1004187	MK FIXING UNIT 'UT' TYPE	40	ADT
1006055	TB7 SLIDING HANGER SET	12	TK
Instead of (come back cw stock)			
1004245	MK FIXING UNIT 'L' TYPE	40	TK
1004256	TB JOINT UNIT	12	TK

Without this hamper the smooth flow of installation work.

We need your kind consideration.

Regards,

**Meftahul Zenan | CROSS WORLD POWER LIMITED** | Engineer, Engineering Dept. | Plot 1/B, Road 98, Gulshan 2, Dhaka 1212, Bangladesh | p: (880 2) 5881 1858, 989 1442 | f: (880 2) 5881 5160 | w: [www.cross-world.com](http://www.cross-world.com)

 please consider the environment before printing this email

This communication contains information which is confidential and may also be privileged. It is for the exclusive use of the intended recipient(s).

**From:** Sazida [mailto:sazida@cross-world.com]

**Sent:** Wednesday, January 17, 2018 10:10 AM

**To:** 'Meftahul Zenan'

**Cc:** sultan@cross-world.com; iftekhar@cross-world.com; 'Maruf Ahmed'; moshiur@cross-world.com; sultan@cross-world.com; haroon@cross-world.com

**Subject:** RE: Absoulte wear ltd.

Dear apu,