

WARRANTY CLAIM FORM

BBT

Project Name:	Unitex Composite Mills Ltd	Date:	15/04/2018
Address:	Bashbaria, Sitakunda, Chittagong		

Date Of Installation:	4/8/2017 ✓	Date Of Damages:	13/04/2018
-----------------------	------------	------------------	------------

Description of Damages:	Found panel connection unit phase to phase Insulation damaged, measured load current L1 2172A, L2 1998A, L3 2056A
-------------------------	--

Replaceable Goods:	CODE	DESCRIPTION	QUANTITY	UNIT
	3013929	KXA 33504-B-P11-3200A- BOLT ON PANEL CONNECTION-4W (DISTRIBUTION BOARD CONNECTION UNIT) ✓	1	pc
	3011691	KXA 33504-B-X-3200A- BOLT ON SPECIAL LENGTH-4W (X=600, QUANTITY 1) ✓	1	pc

Remarks:

Image/Sample Attached	YES ☒ NO ☐
-----------------------	---

Reported By:	Remon Das	Designation:	Engineer
--------------	-----------	--------------	----------

[Signature]
15/4/18
Signature & Date

Recommendation for replacement:

Approved By:

HOD

COO/ GM-Sales

Availability (To be filled by Store Department)

Ready Stock :	YES ☐	NO ☐	PARTIAL ☐
---------------	------------------------------	-----------------------------	----------------------------------

Available goods for replacement in Ready Stock :	CODE	DESCRIPTION	QUANTITY	UNIT
	3013929		01	Pcs

Goods to import for replacement :	CODE	DESCRIPTION	QUANTITY	UNIT
	3011691	Goods to import for replent.	01	Pcs

Status of Technical & Commercial matter:

Financial Approval

[Signature]
Signature & Date

Unitex Picture for Warranty Claim:

