

WARRANTY CLAIM FORM

BBT

Project Name:	Hatil Complex Ltd.	Date:	3/2/2019
Address:	Kashimpur, Gazipur.		
Date Of Installation:	28/03/2018	Date Of Damages:	19/12/ 2018
Description of Damages:	KOP 0851-B1-80 A-PLUG-IN-TAP-OFF BOX-EMPTY-OPENABLE WINDOW-5W		
Replaceable Goods:	CODE	DESCRIPTION	QUANTITY
	3048647	KAP 0404 -STD-40A Standard Length - 6W	1 (3 meter)
	3025109	KAP 32-W plug-in Tap off box	1
Remarks:	L1 Burnt due to loose contact, may be failure of locking of TOB.		
Image/Sample Attached	YES ☒ NO ☐		
Reported By:	Md. Fahim Muntasir	Designation:	Assistant Engineer
Recommendation for replacement:		Signature & Date	
Approved By:		COO/ GM-Sales	
Availability (To be filled by Store Department)			
Ready Stock :	YES ☒ NO ☐ PARTIAL ☐		
Available goods for replacement in Ready Stock	CODE	DESCRIPTION	QUANTITY
	3048647		01 (3 meter) Pcs
Goods to import for replacement :	CODE	DESCRIPTION	QUANTITY
	3025043		01 Pcs
Status of Technical & Commercial matter:			
		Financial Approval	
		Signature & Date	