




WARRANTY CLAIM FORM

BBT

Project Name:	Premiar Printing Press	Date:	23/07/2019	
Address:	Demra, Dhaka.			
Date Of Installation:	Installation ongoing	Date Of Damages:	Delivery. 02/07/19	
Description of Damages:	3015504 - KXA 1250-B-B10 - 1250A BOLT ON FEEDER BOX-4W (FEEDER BOX)			
Replaceable Goods:	CODE	DESCRIPTION	QUANTITY	UNIT
	3015504	KXA 1250-B-B10 - 1250A BOLT ON FEEDER BOX-4W (FEEDER BOX)	1	Pcs.
Remarks:				
Image/Sample Attached	YES <input checked="" type="checkbox"/>	NO <input type="checkbox"/>		
Reported By:	Md. Fahim Muntasir	Designation:	Assistant Engineer	
Feeder Box housing & connector are not matching to parallel of KXA 1250A BBT housing & connector.				
Recommendation for replacement:				
Approved By:	HOD		COO/ GM-Sales	
Availability (To be filled by Store Department)				
Ready Stock :	YES <input type="checkbox"/>	NO <input type="checkbox"/>	PARTIAL <input type="checkbox"/>	
Available goods for replacement in Ready Stock :	CODE	DESCRIPTION	QUANTITY	UNIT
	3015505	1250A Bolt on Feeder Box-5W	01	Pcs
Goods to import for replacement :	CODE	DESCRIPTION	QUANTITY	UNIT
Status of Technical & Commercial matter:				
Financial Approval				
				
Signature & Date				