

19 September 2019

Cross-world



### NOTE FOR APPROVAL

1	<b>Subject</b>	Gen-set re-export of Samytex Industries Ltd to UK for repair.
2	<b>Background</b>	<p>Samytex Industries Ltd. purchased one PM600 Generator from AML by opening L/C (No. 0000000116010133 dated 24.03.2016.) The PM600 (Plant ID 16E12401B) had its engine crankshaft damaged after 28 running hours. Warranty was claimed from Perkins through Energypac and they replaced the engine. But the replacement engine, has also seized and Energypac appeared to leave the problem without any indication of resolution.</p> <p>Since the process is taking long time and to resolve the matter immediately, AML agreed to take the responsibilities to repair the generator. Thus, we have to return the generator to AML premises by our own arrangement. The cost of shipping to the UK will be upon us.</p> <p>This note is to document the consent of the meeting outcome held in presence of the CEO, Head of SCM, Senior Manager (Commercial), where it is decided to send the faulty DG with CWPL cost.</p>
3	<b>Objective</b>	The objective of this fact sheet is to brief the Management on this issue and sought approval for re-export of the damaged gen-set.
4	<b>Costing &amp; Commercials</b>	<p>Approximate Cost details are:</p> <p>Ex ICD Dhaka – Hull port UK/20'dc Hull port to door delivery (AML) total AML to CTG port Total</p>
5	<b>Recommendation</b>	Based on above, approval is requested for further process to re-export the set immediately.

### Approval

	Name	Remarks	Sign-Off	Date
Initiated by	Farhana Khan Usha			19/9/2019
Checked by	Kazi Lutful Hoque			19/9/2019
Endorsed by	Maruf Ahmed			24/9/19
Endorsed by	Mohammad Sayeful Islam Khan	<i>Under Remarks</i> <i>Cost</i>		24/09/2019
Approved by	Syed Raziur Rahman Chowdhury			24/09/2019