

Ref: Admin-01/WO/Gen-set/2016/

October 23, 2016

Chairman & CEO
Cross World Power Limited (CWPL)
House 6, Road 92, Gulshan - 2,
Dhaka 1212, Bangladesh

Attn: Mr. Md. Ariful Islam, Manager, Sales.

Sub: Work Order for Electric & Generator Load Distribution & Control Mechanism at Z N Tower,
Gulshan, Dhaka.

Dear Sir,

Reference to your quotation regarding the subject matter, the management of the bank has awarded your company to complete the task as per below details:

SL	Particulars	Qty	Rate (Tk)	Cross World Power Ltd
1	Powder Coated Metal Box	1 Pc	56,667.00	56,667.00
2	Circuit Breaker (160 A, 25 KA, ABB-Italy)	3 Pcs	13,000.00	39,000.00
3	AC Timer (2), Relay (1), Ceramic fuse with casing (3), Indicating lamp (3), Voltmeter with selector switch (1), Copper Bus Bar (1 set) & Connection accessories (1 set).			48,210.00
Total (Part-A)				1,43,877.00
4	Powder Coated Metal Box	1 Pc	38,000.00	38,000.00
5	Copper Bus Bar 350 Amps	1 Set	9,500.00	9,500.00
6	Connection Accessories	1 Set	6,667.00	6,667.00
7	Circuit Breaker (125 A, 25 KA, ABB-Italy)	1 Pc	9,984.00	9,984.00
8	Circuit Breaker (40 A, 16 KA, ABB-Italy)	1 Pc	8,528.00	8,528.00
Total (Part-B)				72,679
Grand Total (A+B)				2,16,556.00

Amount in Words: Taka Two Lac Sixteen Thousand Five Hundred Fifty Six Only.

Terms & Condition of the Work:

Work Location: Z N Tower, Plot # SW (I) - 2, Road # 08, Dhaka. Gulshan - 1.

Work Completion Date: By October 29, 2016.

Caution: Please advise your team to work carefully. You will be held liable for any damage caused to bank premises/Asset during installation.

Penalty: An amount of Tk. 500.00 (Five Hundred) only will be deducted for each day of delay, if the deadline is not maintained without prior notice.

Payment: Payment will be made after successful completion of work and AIT & VAT will be deducted from the bill as applicable.



HEAD OFFICE

Jiban Bima Bhaban

2nd Floor

10, Dilkusha C.A.

Dhaka-1000

Bangladesh

Assign Engr. from Engr. Team.
Mr. Manager
will approved all requisition.
27/10/16

This 2 nos. Color will Same

But, 300 KVA ATS, foreign look, other
Color of 2.


Submission of Bill: Bill/s must be submitted within 01 (one) month of completion of the work. Bank authority will not be liable for bills submitted after unusual delay without any intimation.

Note: Work order for "580 Amps TP AC-3 Duty Magnetic Contactor (ABB-Sweden) of Tk. 309,920.00" will be provided latter after further clarification.

Please note that a satisfactory Certificate/Challan needs to be obtained with the signature and name seal of employee of concerned branch/ office, after successful completion of the above mentioned work for necessary processing at our end.

EBL reserves all the right to cancel this work order without assigning any reason.

Thanking You



Md. Barkat Ullah
Associate Manager, EBL Administration

Accepted by

(Please Sign & Return/Confirm Via Email)


CROSS WORLD POWER LTD.



BOQ OF 250 A ATS							
SL NO	JOB DESCRIPTION	TECHNICAL DETAILS/ BRAND	SCOPE OF SUPPLY	UOM	QTY	UNIT SALE	TOTAL SALE
1	250 AMPS ATS PANEL	Powder Coated Metal Box made with 16 SWG Sheet dimension: (H-1200 X W-600 X D-400) mm , Fabricated by Cross World Power Ltd		No	1	38,000	38,000
		TP+N+E Copper Bus Bar 350Amps (20X10)mm as required in Panel with Connection Facility		Set	1	9,500	9,500
		Connection Accessories		Set	1	6,667	6,667
2	Circuit Breaker	125A, 25kA, TP MCCB with microprocessor based, built in adjustable thermal overcurrent & magnetic short circuit protection (ABB Italy)		Pcs	1	9,984	9,984
		40A, 16kA, TP MCCB with microprocessor based, built in adjustable thermal overcurrent & magnetic short circuit protection (ABB Italy)		Pcs	1	8,528	8,528
NOTE: Existing ATS Box Components will be used in this panel along with new items						Total	72,679



CROSS WORLD POWER LTD.



Ensuring Power Since 1982

BOQ of DB BOX						
SL NO	JOB DESCRIPTION	TECHNICAL DETAILS/ BRAND	UOM	QTY	UNIT SALE	TOTAL SALE
1	DB BOX	Powder Coated Metal Box made with 16 SWG Sheet dimension: (H-1600 X W-800 X D-400) mm and consisting of provision for following items . Fabricated by Cross World Power Ltd	No	1	56,667	56,667
		TP+N+E Copper Bus Bar 800Amps (50X10)mm as required in Panel with Connection Facility	Set	1	23,750	23,750
		Connection Accessories	Set	1	20,000	20,000
2	Circuit Breaker	160A, 25kA, TP MCCB with microprocessor based, built in adjustable thermal overcurrent & magnetic short circuit protection (ABB Italy)	Pcs	3	13,000	39,000
Total						139,417

WO - 1,93,877 F

