

Habibur Rahman

From: Habibur Rahman <habib@cross-world.com>
Sent: Monday, August 21, 2017 12:15 PM
To: Zahidur Rahman (zahidur@cross-world.com)
Subject: FW: Syn. Pannel for 3 genset for apparel puls ltd.
Attachments: BOQ SYNC (Apparel Plus Limited) REQ R1.xlsx; Panel Dwg 20170508 R1.pdf

Importance: High

N.B:- Additional Requirement of Sync Panel

SL NO	TECHNICAL DETAILS	UNIT	QTY			
	INCOMING			Hyundai	ABB	Difference
1	1000A, TP Fixed type 66kA ACB with closing solenoid and store -energy spring charged operating with closing solenoid and store -energy spring charged operating mechanism and solid state microprocessor controlled adjustable thermal overload and short-circuit releases with following accessories:	No	1	1,50,900	3,10,000	1,59,100
	1 X Closing Coil					
	1 X Gear motor for spring charge					
	1 X Under Voltage Release					
	Brand : ABB					
2	400A, AC3, TP Magnetic Contactor	No	1	31,000	90,000	59,000
	AUX 2NO 2NC					
	Brand : ABB					
3	Incoming & Outgoing Busbar for 1x1000A ACB (1x60mmx10mm) TP	Meter	4	Existing use		
4	Incoming & Outgoing Busbar for 1x400A MC (1x30mmx10mm) TP	Meter	4	Existing use		
Total (BDT)						2,18,100

Sincerely,

26/08/2017

Approved :- \$1,80,000/-
Payment :- 50% Advance 50% After Installn
26/08/17