

650KVA DG-1 SYNC BOQ					
SL NO	TECHNICAL DETAILS	UNIT	QTY	UNIT RATE	TOTAL RATE
1	SUPPLY & INSTALLATION				
	Tmax T7S 1000 PR231/PLS/I In= 1000A 3p FFM 1000A 50kA TP Moulded Case Circuit Breaker MCCB (1SDA062754R1)	No	1	110,219	110,219
	Gear Motor for MCCB T7M-X1 240-250V AC (1SDA062116R1)	No	1	32,363	32,363
	Shunt Closing Release for MCCB T7M-X1 240-250V AC/DC (1SDA062081R1)	No	1	9,709	9,709
	Under Voltage Release T7M-X1 220-240V AC (1SDA063552R1)	No	1	9,709	9,709
	Auxiliary Contact T7M-X1 2Q 400V AC (1SDA062102R1)	No	1	8,784	8,784
	Current Transformer, ratio: 1200/5A, 5VA Class-1 with suitable accuracy and burden	Nos	3	2,338	7,015
Total TK (Excl VAT & AIT)					177,799

Discount 3% (C)

5384

Bill Amount = 172,415/-

12/12/17

CROUS WORLD POWER LIMITED
BOQ OF 2X650 KVA GENERATOR INSTALLATION MATERIAL

CLIENT: APEX HUSAN		ADDRESS: Savar		DATE: 05/12/17				
GEN MODEL:		ENGINE MODEL:		ALTERNATOR MODEL:				
SL NO	JOB DESCRIPTION	TECHNICAL DETAILS/ BRAND	SOS	UOM	QTY	UNIT RATE	TOTAL RATE	REMARKS
01	Electrical System							
11	Power Cable Laying	240mm 240mm VV Power Cable Laying execution work by (two)		meter	250	104	26,000	
4	Commissioning Material			liter	120	180	21,600	
4.1	Radiator coolant	Pressure Proofing Contact		liter	130	400	52,000	
4.2	Lube oil	Delvac GAS S X 40		liter	80	59	4,720	
4.3	Battery electrolyte	Specific gravity 1.250						
Total TK (Excl VAT & AIT)							104,320	

P.C.
 12/12/17