

3323

Md. Abusieed Sobuj**Subject:**

FW: 1x100 KVA genset commissioning at SCL Uttara core

From: Ashim Kumar Roy [mailto:ashim.roy@summitcommunications.net]**Sent:** Tuesday, August 28, 2018 10:48 AM**To:** 'Md. Moazzem Hossain'**Cc:** sultan@cross-world.com; 'Habibur Rahman'; 'Md. Rubel Khan'; 'Kowshik Mushfiquir Rahman'; 'Rafi Vai'; 'Md. Abusieed Sobuj'; zia@cross-world.com; surajit.saha@summitcommunications.net**Subject:** RE: 1x100 KVA genset commissioning at SCL Uttara core**Dear Concerned,**

Please go forward with your revised BoQ and take initiatives for this ducting incorporation at your earliest.

Looking forward to your co-operation.

Thanks with Regards,

Ashim Roy

Assistant Engineer || Power & Project || Summit Communications Limited

Cell: +8801670357453 || Email: ashim.roy@summitcommunications.net

From: Md. Moazzem Hossain [mailto:moazzem@cross-world.com]**Sent:** Wednesday, August 08, 2018 5:23 PM**To:** 'Ashim Kumar Roy'**Cc:** sultan@cross-world.com; 'Habibur Rahman'; 'Md. Rubel Khan'; 'Kowshik Mushfiquir Rahman'; 'Rafi Vai'; 'Md. Abusieed Sobuj'; zia@cross-world.com**Subject:** RE: 1x100 KVA genset commissioning at SCL Uttara core**Dear Ashim Bhai,**

As discussion over phone, please check the revised Exhaust Silencer straight Pipe BOQ as mentioned below.

SI No	Job Description	Tehcnical Details/ Brand	Unit	Quantity	Unit Price (BDT)	Total Price (BDT)
1	Exhaust Silencer straight Pipe	MS Pipe bore 4" ,thickness 4mm	Feet	05	492	2460
2	Exhaust Silencer straight Pipe	MS Pipe bore 6" ,thickness 4mm	Feet	40	1250	50000
3	Reducer 4" – 6" Dia		Pcs	1	1250	1250
4	Exhaust Bend- 6"	6 inch Dia	Pcs	2	1447	2894
5	Exhaust Flange- 6"	6 inch Dia	Pcs	6	855	5130
6	Exhaust Heat Insulation		Feet	45	329	14805
7	Exhasut Fitting	All bracket , support must be made with MS angle 50X50X 4, 5 & 6 MM	Feet	45	263	11835
					Total:	88,374

Here we need your approval with a mail against above mention quotation.

Best regards,

Md.Moazzem Hossain | **CROSS WORLD POWER LTD** | Sr.Executive,Commissioning | Plot 1/B, Road 90, Gulshan - 2, Dhaka 1212, Bangladesh| p: +880 2 5881 1858, 989 1442 | f: +880 2 5881 5160 | m: +8801755-514733| moazzem@cross-world.com | w: www.cross-world.com