



# Advanced Chemical Industries Ltd.

Forms No.7-09-01-03

209, BSCIC I/A, Tongi, Gazipur

Head Office: ACI Centre, 245, Tejgaon I/A, Dhaka-1208, Tel: 880-2-8878603-10, Fax: 880-2-8878622.



Cross World Power Limited [01180897]

Plot 1/B, Road 90, Gulshan - 2, Dhaka 1212, Bangladesh

E-TIN : 287375911315

VAT Registration No. : 000421293

Purchase Order No. : 1809000743

Purchase Order Date : 11/09/2018

Business : Electrical

VAT Registration No. : 18041027170

CEP No. : ACI/286/2018

Created By : Rakhi Halder

Please supply and deliver the following items subject to the instructions and conditions set out below and on the reverse side hereof

SL No.	Description	Product Code	Unit	Quantity	Unit Price (Taka)	Amount (Taka)
1	Installation Items for Diesel Generator as per attached BOQ	5000016811	Lot	1.00	43,000.00	43,000.00
						43,000.00
Taka : Forty Three Thousand Only.						43,000.00

Remarks :

Delivery Date : On or before : After confirmation by us  
Place of Delivery : ACI Electrical Factory, Tongi  
Delivery terms : Transportation: Included  
Documents of Delivery : Delivery must be made under your delivery challan quoting this Purchase Order No.  
Invoicing : Invoice should be submitted in duplicate alongwith copy of Delivery Challan, VAT Challan (if applicable) & necessary certificates by an authorized ACI employee  
Payment Terms : Payment will be made within 7 working days from the date of bill submission  
Replacement : Supplier should return or replace non-conforming or defective or if it doesn't match with mentioned specification & performance.  
Transport cost : Loading & Carriage cost Included.  
VAT & Tax : VAT & Taxes will be applied as per Govt. Regulation.

PLEASE ACKNOWLEDGE RECEIPT OF THIS ORDER BY SIGNING ON THE DUPLICATE COPY AND RETURN THE SAME TO THE COMPANY IN ACCEPTANCE OF THE ORDER

For Advanced Chemical Industries Ltd.

*[Signature]*

*[Signature]*  
Nur Mohammad Feroz  
Materials Controller



## ACI Limited

Business: Electrical

### BOQ of Installation Items for 100KVA Diesel Generator

CEP NO: ACI/286/2018; CEP Date: 02/08/2018

1	Generator Earthing		Unit	QTY
1.1	Earthing Block	Dimension LXWxD - 250mm X 20mm X 5mm with connection facility	Pcs	1
1.2	Earthing Cable	1 X 16 mm BYA (Green ) from Earthing Copper bar to gen & equipment	Meter	5
1.3	Earthing Cable lugs	16 mm <b>Material</b> -Copper , <b>Surface</b> - Electro Tinned	Pcs	6
2	<b>Exhaust System:</b>			
2.1	Exhaust Silencer straight Pipe	MS Pipe bore 3" ,thickness 3-4mm	Meter	4
2.2	Exhaust Bends /Elbow	Long radius 90 deg L bow 3"	Pcs	2
2.3	Exhaust Socket	Threaded 3"dia MS Socket	Pcs	1
2.4	Exhaust Heat Insulation	Insulation Of Pipe with Glasswool (25.4mm min thickness) along with 26SWG Aluminium sheet cladding.	Job	1
2.5	Exhasut Fitting	All bracket , support must be made with MS angle 50X50X 4, 5 & 6 MM	Job	1
3	<b>Cooling System:</b>			
3.1	Radiator Ducting	As per layout with 22 SWG MS sheet,Angle bar, flat bar support,Canvas cloth etc	Sq-ft	50
3.2	<b>Commissioning Material:</b>			
3.3	Radiator coolant	Havoline Premix Coolant	Liter	15
3.4	Lube oil	SAE 15 W 40	Liter	10
3.5	Battery electrolyte	Specific gravity 1250	Liter	10
3.6	<b>DG On site delivery:</b>			
3.7	Loading /Unloading/Lifting	Generator dry weight-2600 Kg	<b>CWPL</b> Job	1

10  
Jahan  
11/09/2018

R. Son  
11/09/2018