

Md. Al- Miraj

From: Md. Mahfuzul Islam Rizve <mahfuz@cross-world.com>
Sent: Monday, October 08, 2018 10:11 AM
To: 'Md. Abusieed Sobuj'
Cc: Moazzem@cross-world.com; 'Habibur Rahman'; 'Al-Miraj'
Subject: FW: Installation materials offer of Anwar Landmark Beg Perk View Project
Attachments: BOQ_ANOWAR_LANDMARK_Beg Park View.xlsx

Dear Brothers,

Please see the below mail for client approval, please see the attached file and take necessary action for complete the installation work of this project as early as possible.

Best regards,

Md. Mahfuzul Islam Rizve | **CROSS WORLD GROUP** | Senior Engineer, Sales | Plot 1/B, Road 90, Gulshan - 2, Dhaka 1212, Bangladesh | Phone: +880 2 5881 1858, 989 1442 | Mobile No: **01755-694131, 01712940082** | Fax: +880 2 5881 5160 | E-mail: mahfuz@cross-world.com | web: www.cross-world.com

 please consider the environment before printing this email



From: Abdullah Al-Mamun, AGM(Electrical), ALML [<mailto:abdullah.mamun2@anwargroup.net>]
Sent: Monday, October 08, 2018 9:05 AM
To: Md. Mahfuzul Islam Rizve
Cc: herobhattacharjee1@gmail.com
Subject: RE: Installation materials offer of Anwar Landmark Beg Perk View Project

Dear concern please arrange the required cable & make the job done...

mamun

From: Md. Mahfuzul Islam Rizve [<mailto:mahfuz@cross-world.com>]
Sent: Sunday, October 07, 2018 9:58 AM
To: Abdullah Al-Mamun, AGM(Electrical), ALML

Cc: herobhattacharjee1@gmail.com

Subject: Installation materials offer of Anwar Landmark Beg Perk View Project

Dear Sir,

Please give me your approval for control cable and communication Shield Cable supply **as per attached BOQ price** for your Beg Park View project as early as possible.

Best regards,

Md. Mahfuzul Islam Rizve | **CROSS WORLD GROUP** | Senior Engineer, Sales | Plot 1/B, Road 90, Gulshan - 2, Dhaka 1212, Bangladesh | Phone: +880 2 5881 1858, 989 1442 | Mobile No: **01755-694131, 01712940082** | Fax: +880 2 5881 5160 | E-mail: mahfuz@cross-world.com | web: www.cross-world.com

 please consider the environment before printing this email



BOQ OF 500kVA & 300kVA GENERATOR

DATE- 7.10.18

ALTERNATOR MODEL-

SL NO	JOB DESCRIPTION	TECHNICAL DETAILS/ BRAND	SCOPE OF SUPPLY	UOM	QTY	UNIT RATE	TOTAL RATE	REMARKS
1	Electrical System:							
1.1	Control cable For Sensing	4 X 1.2 rm (40/0.19 mm)Flexible Cable		Meter	35	105	3675	
1.2	Communication Shield Cable	2 X 1.2 rm screened cable, 120Ω resistance			50	250	12500	
						Total:	16175	

* ABOVE MENTIONED INSTALLATION MATEIRAL WITHOUT CIVIL WORK QUANTITY, NECESSAY CIVIL WORK MUST DONE BY CLIENT AS PER CWPL ENGINNER INSTRUCTION.