

Md. Abusieed Sobuj

Subject: FW: RE: Diesel generator (300 KVA) silencer pipe repositioning at After Hours Hotel & Resorts.

-----Original Message-----

From: vgl.hanif@isotechgrp.com [mailto:vgl.hanif@isotechgrp.com]

Sent: Monday, December 10, 2018 11:25 AM

To: Md.Abusieed Sobuj

Cc: Zafur2000@gmail.com; vgl.miftha@isotechgrp.com; itg.sharif@isotechgrp.com; ziaul islam; Sultan Sakauat Sarkar; Sohel Uddin Bhuiyan; Nabbi Ferdous Rafi; Md. Habibur Rahman Javed; Harunor Rashid; Md.Moazzem Hossain

Subject: Re: Diesel generator (300 KVA) silencer pipe repositioning at After Hours Hotel & Resorts.

Dear Mr Shobuj,

We approved your mentioned quotation.please do proceed and take necessary steps to complete the repositioning task.

Thanks///

From: Md. Abusieed Sobuj [mailto:sobuj@cross-world.com]

Sent: Sunday, December 09, 2018 3:58 PM

To: vgl.hanif@isotechgrp.com

Cc: 'Zafur2000@gmail.com'; 'vgl.miftha@isotechgrp.com'; 'itg.sharif@isotechgrp.com'; zia@cross-world.com; sultan@cross-world.com; sohel@cross-world.com; 'Rafi Vai' (rafi@cross-world.com); 'Habibur Rahman' (habib@cross-world.com); harunor@cross-world.com; moazzem@cross-world.com

Subject: RE: Diesel generator (300 KVA) silencer pipe repositioning at After Hours Hotel & Resorts.

Dear Hanif Bhai,

As discussed with you on site, please have a look on below table BOQ for additional rework of Exhaust System at **After Hours Hotel & Resorts**.

SL NO	JOB DESCRIPTION	TECHNICAL DETAILS/ BRAND	SCOPE OF SUPPLY	UOM	QTY	UNIT RATE	TOTAL RATE	REMARK
1	Exhaust System:							
1.1	Exhaust Silencer straight Pipe	supply of MS Pipe bore 6" ,thickness 3-4mm		Meter(Approx.)	1	4,100.00	4,100.00	
1.2	Exhaust Heat Insulation	Insulation Of Pipe with Rockwool (25.4mm min thickness) along with 26SWG Aluminum sheet cladding.		Job	1	1,079.00	1,079.00	
1.3	Exhaust Fitting	All bracket , support must be made with MS angle 50X50X 4, 5 & 6 MM		Job	1	863.00	863.00	
1.4	Re-works of existing Exhaust Silencer straight Pipe	Dismantle of existing exhaust System - length-6m, (MS Pipe bore 6" ,thickness 3-4mm) and Re- Installation with fitting of Exhaust System -6m		Job	1	11,250.00	11,250.00	

TOTAL(BDT): 17,292

Here need your approval mail against above mention quotation.

Best Regards

Md. Abusieed sobuj | CROSS WORLD LTD | Engineer, Managed Service Division | Plot 1/B, Road 90, Gulshan 2, Dhaka 1212, Bangladesh | p: +880 2 5881 6528, 989 1442 | f: +880 2 5881 5160 | Mobile No: +088 01755514856 | e: sobuj@cross-world.com | w: www.cross-world.com

-----Original Message-----

From: Md. Abusieed Sobuj [<mailto:sobuj@cross-world.com>]

Sent: Wednesday, December 05, 2018 5:04 PM

To: 'vgl.hanif@isotechgrp.com'

Cc: 'Zafur2000@gmail.com'; 'vgl.miftha@isotechgrp.com'; 'itg.sharif@isotechgrp.com'; zia@cross-world.com; sultan@cross-world.com; sohel@cross-world.com; 'Rafi Vai' (rafi@cross-world.com); 'Habibur Rahman' (habib@cross-world.com); maruf@cross-world.com; harunor@cross-world.com

Subject: RE: Diesel generator (300 KVA) silencer pipe repositioning at After Hours Hotel & Resorts.

Dear Sir,

Please be informed that, we already completed our all scope of work, DG test run and handed over the generator last Monday on 03.12.18 as per your present load(L1-56A, L2-117A, L3-87A), because PDB power still not available at site. So Please inform us when the PDB power will be available then we will send a team to complete the ATS MC(PDB End) connection. In this circumstances, we are requesting to provide rest of payment according to existing WO.

Also informed you that, the below mail reference tomorrow we will send the execution BOQ for additional rework of Exhaust System.

Best Regards

Md. Abusieed sobuj | CROSS WORLD LTD | Engineer, Managed Service Division | Plot 1/B, Road 90, Gulshan 2, Dhaka 1212, Bangladesh | p: +880 2 5881 6528, 989 1442 | f: +880 2 5881 5160 | Mobile No: +088 01755514856 | e: sobuj@cross-world.com | w: www.cross-world.com

-----Original Message-----

From: vgl.hanif@isotechgrp.com [<mailto:vgl.hanif@isotechgrp.com>]

Sent: Wednesday, December 05, 2018 3:20 PM

To: sobuj@cross-world.com

Cc: Zafur2000@gmail.com; vgl.miftha@isotechgrp.com; itg.sharif@isotechgrp.com

Subject: Diesel generator silencer pipe positioning

Dear Mr.Shobuz,

As per management decision due to sound problem of diesel generator silencer it needs to change its position. To attenuate the sound level the location should be at road side in proper height.

Also Please Send me the BOQ based on changing silencer position.

Thanks//

Md Abu Hanif

Sr.Ex.Engineer(Electrical)

ISOtech group.