

Commissioning Materials @ Commissioning Confirmation

CROSS WORLD POWER LIMITED

BOQ OF XXX KVA GENERATOR

CLIENT - EBL, Khulna

ADDRESS- Khulna

DATE- 23.10.19

GEN MODEL-

ENGINE MODEL-

ALTERNATOR MODEL-

ELECTRICAL INSTALLATIONS							
SL NO	JOB DESCRIPTION	TECHNICAL DETAILS/ BRAND	SCOPE OF SUPPLY	UOM	QTY	UNIT RATE	TOTAL RATE
1	Electrical System:						
1.1	PVC Tape	Adhesive Tape 04 color (Red/Yellow/Black/Blue)		Pcs	4	29	116
1.2	Royal Bolt	10 no.		Pcs	10	18	180
2	Exhaust System:						0
2.1	Exhaust Silencer straight Pipe	MS Pipe bore 3", thickness 3-4mm		Feet (Approx)	10	526	5262
2.2	Exhaust Bends/Elbow	Long radius 90 deg L bow		Pcs	2	724	1448
2.3	Exhaust Heat Insulation	Insulation Of Pipe with Rockwool/Glasswool (25.4mm min thickness) along with 26SWG Aluminium sheet cladding.		Job	1	1579	1579
2.4	Exhaust Fitting	All bracket, support must be made with MS angle 50X50X 4, 5 & 6 MM		Job	1	1317	1317
Total Tk- (including VAT & Tax)							9908

100% after installation

15,000/-
including VAT
to Tax
23.10.19