



INDO-BANGLA
PHARMACEUTICALS LTD.
Good Health Good Life

IBPL-185/2020

Dated: 29.11.2020

Cross World Power LTD

Plot 1/B, Road 90, Gulshan gulshan-2

Subject: Work order for Generator insulation exhaust system, and Manual changeover switch for 650KVA 3 phase heavy duty diesel generator set.

Dear Sir,

As per your quotation of CWPL-AM/6122/20F dated October 17, 2020 technical offer CWPL-AM/6122/20T and CWPL-AM/5887/20F technical offer #CWPL-AM/5887/20T to Indo-Bangla Pharmaceuticals Ltd. We are hear by confirmed you and providing order to supply generator insulation, exhaust system and local canopy for 650KVA generator. Please received this work order and take necessary steps accordingly.

SL No	Description	Technical Details	Quantity	Unit Rate (Taka)	Total Rate (Taka)
01	Exhaust Silencer Straight pipe	MS Pipe, Bore 200 Mm, thickness 3-4 mm	9 Miter	4,532.00	40,788.00
02	Exhaust Brands/Elbow	Long radius 90° Elbow diameter 200 mm bore	1 pcs	2,117.00	2,117.00
03	Exhaust Flange	Welding neck flange 200 mm bore	4 pcs	1,118.00	4,472.00
04	Exhaust heat insulation with 1nos silence box	Insulation of pipe with Rockwool / glass wool (25.4 mm Aluminium sheet ducting	1 job	37,177.00	37,177.00
05	Manual change over switch (MCOS)	1200A (TPN) hard drawn electrolytic copper bus-bars of 60mm x 10mm bus-bar size enclosure will be made by 16 SWG sheet Metal with good quality powder coat.	2 nos	95,000.00	1,90,000.00
Grand Total :					2,74,554.00

In word: - Two Lac Seventy Four Thousand Five Hundred and Fifty Taka only.




INDO-BANGLA
PHARMACEUTICALS LTD.
Good Health Good Life

Terms & Condition:

01. Delivery is to be made at our factory: Indo-Bangla pharmaceuticals, College Road Barisal.
02. We give you 50% advance payment as at account payee check
03. Rest amount will be given after completion of successful work.
04. While you are submitting the bill, You must submit the work order and delivery challan along with bill
05. To completion this work any type of accessories or any job is your responsibility
06. we hope you complete the work within short time
07. Exhaust piping system (SL No. 1-4) may be deviated according to site condition
08. You must install the manual change over switch.

Thanking You,


A.F.M Anowarul Huq
29-11-20

Managing Director

Indo-Bangla Pharmaceuticals Ltd