



SAYED ELECTRIC & CO.

Engineers ■ Builders ■ Importers ■ Suppliers
& Special Class Government Contractors

সৈয়দ ইলেকট্রিক এন্ড কোং

প্রকৌশলী, নির্মাতা, আমদানীকারক, সরবরাহকারী
ও বিশেষ শ্রেণীর সরকারী ঠিকাদার

Ref: SM/WO/BB/MYM/03/2021.

Date: 28/02/2021.

To

CEO

CROSS WORLD POWER LTD.

Plot 1/B, Road 90, Gulshan - 2, Dhaka 1212, Bangladesh.

Attention: Ariful Islam (Manager, Sales).

Subject: Work order for Supply of following Equipment's as per your Offer for Bangladesh Bank, Mymensingh office, Mymensingh.

Project: Bangladesh Bank, Mymensingh.

Ref. No : CWPL/SS/BB/20072020. (A).

Dated: 20/07/2020.

Ref. No : CWPL/SS/BB/20072020. (B).

Dated: 20/07/2020.

Ref. No : CWPL/BBT-221/120.

Dated: 20/07/2020.

Ref. No : Generator. (Refer by Mailed).

Dated: 20/07/2020.

Dear Concern.

With due respect, we like to place the work order for LT Switchgear Panel-1 Set, ELT Panel (ATS Panel) -1 Set, 750 KVAR PFI Plant -1 Set, 500 KVA & 200 KVA Diesel Generator with foreign Canopy Set -1 Set, Generator Synchronizing Panel -1 Set, Floor MDB-1-1 Set, Floor MDB-2-1 Set, Floor MDB-3-1 Set, Floor MDB-AC-1 Set, Server MDB-1-1 Set, Busbar Trunking System (with Installation) BBT-1 (2000A) 1 Lot, BBT-2 (1250A) 1 Lot, BBT-3 (1250A) 1 Lot), Server SDB -1 Set, AC SDB-1 -1 Set,, AC SDB-2 -4 Set, SDB Gate House 1 Set, SDB-M -1 Set as your financial Offer.

Total Work Order Value:

CWPL/SS/BB/20072020. (A).	BDT: 2,926,000/=
CWPL/SS/BB/20072020. (B).	BDT: 29,259,900/=
CWPL/BBT-221/120.	BDT: 4,710,000/=
Generator (Ref. Mailed)	BDT: 7,700,000/=
Total Value	BDT: 44,595,900/=

(Taka: Four Crore Forty-Five Lac Ninety-Five Thousand and Nine Hundred Only)



SAYED ELECTRIC & CO.

Engineers ■ Builders ■ Importers ■ Suppliers
& Special Class Government Contractors

সৈয়দ ইলেকট্রিক এন্ড কোং

প্রকৌশলী, নির্মাতা, আমদানীকারক, সরবরাহকারী
ও বিশেষ শ্রেণীর সরকারী ঠিকাদার

Ref:

Date :

Terms & Conditions:

01. Drawing must be provided within 15 days from the Advance Payment date.
02. Goods must be delivered Within 180 days after receipt of confirmed order.
03. Payment Method:
 - i) Advance 20% payment As Token By 10/03/2021.
 - ii) Rest 20% payment After Receiving Drawing.
 - iii) Rest 50% payment After receiving the equipment's at site.
 - iv) Final 10% payment after Installation.
04. Warranty will be provided One year after Commissioning or One & Half year from the date of Delivery.

Thanking You.

Syed Mosharrof Hossain,

Proprietor.

SAYED ELECTRIC & CO.

Contact: +8801714066725.

REF : CWPL-BBT/0066/21F

DATE : Feb 25, 2021

Sayed Electric & CO. Ltd.

5/17, Humayun Road, Block-B, Mohammadpur, Dhaka.

COMMERCIAL OFFER**Sub : Sale Offer for supply of Busbar Trunking Spare Items.**

SL #	Code	Product Name	Unit	Price (BDT)	Qty.	Total Price(BDT)
1)	CWPL-PR-0035-21	BBT 01 (copper 2000A TP N PE)	Lot	2,000,000.00	1.00	2,000,000.00
2)	CWPL-PR-0036-21	BBT 02 (copper 1250A TP N PE)	Lot	1,200,000.00	1.00	1,200,000.00
3)	CWPL-PR-0037-21	BBT 03 (copper 1250A TP N PE)	Lot	1,050,000.00	1.00	1,050,000.00
4)	CWPL-PR-0038-21	Offer for manpower charge for Installation, testing & Commissioning of the above BBT (without any materials)	Job	60,000.00	1.00	60,000.00
5)	CWPL-PR-0039-21	Offer for interconnecting copper Bar BBT Flange end to panel CKT breaker	Job	400,000.00	1.00	400,000.00
Total Price (in BDT) =						4,710,000.00
Grand Total (in BDT without VAT) =						4,710,000.00

Terms & Conditions:

01. Offer Validity : 10 days from the date of this offer.

02. Brand : EAE.

03. Country of Origin : Turkey.

04. Delivery Time : 2 Working Days from the date of W/O along with advance.

05. Payment : 100% Advanced along with Work Order.

06. Warrantee : We warrantee the goods of any manufacturing defects in materials for a period of 1 years from the date of Delivery.

Your truly,

CROSS WORLD POWER LTD.

Md. Ariful Islam

Manager, Sales & Marketing

Mobile : 01755 514 731



EAE Elektrik Asansör End.
İnşaat Sanayi ve Ticaret A.Ş.
İst. Tic. Sic. Mük. No: 121069
Marmara Kurumlar V.D. 323 004 2973
Mersis No: 0323004297300014
Kep mail: eae@elektrik.asansor.com.tr
Kep İhtis No: 290773602
Akçaburgaz Mahallesi, 3114. Sokak No: 10
Esenyurt 34522 İSTANBUL
T: 0 (212) 866 20 00
F: 0 (212) 866 24 20
www.eae.com.tr

Specifications Submission and Compliance Sheet (Form PG3-5)

Invitation for Tender No: 20/mymensingh/SST/2020-32 Date: 11/06/2020
Tender Package No: N/A Package Description: Single
Tender Lot No: N/A Lot Description: Single

Instruction to fill-up:

*To be filled up by the Tenderer & Manufacturer in letterhead pad with appropriate data as per manufacturer specification, otherwise the tender shall be rejected.

* Must mention specific value/data model, brand & origin as per manufacturer offered model specification; **should not write complied or as per required/specification**, as it is not GTP rather specification submission sheet.(Page 91-140)

*All incoming & outgoing ACB of LT Panel shall be installed in single enclosure/cubicle.

Item No.18 BusBar Trunking System:

Description	Bangladesh Banks Requirement	Tenderers offered Specification
Brand and Model	Mentioned by bidder	EAE KXC
Manufacturing Standard	ISO 9001, ISO 14001, OHSAS 18001 & IEC 61439-6 Type test from KEMA/ASTA	ISO 9001, ISO 14001, OHSAS 18001 & IEC 61439-6 Type test from KEMA/DEKRA
Seismic Test	Seismic Tested from European Lab otherwise bid shall be rejected	Tested in Zone 4 from VIRLAB, S.A.
Safety	IEC/HD 60364-4-41, Clause A	IEC/HD 60364-4-41, Clause A
Country of Origin	USA/UK/EU/Turkey/Japan or equivalent	Turkey
Name & Address of Manufacturer (with e-mail) plant	(Address Mentioned by bidder)	EAE ELEKTRİK Akçaburgaz Mh., 3114.Sokak No:10, 34522 Esenyurt/İstanbul, Turkey caydemir@eaegroup.com
Operating voltage	415V	415V
Operating Frequency	50Hz	50Hz
Maximum ambient temperature	40deg.C	40deg.C
Degree of protection	IP55	IP55
Colour	Approved Color	Gray
Over Voltage Category	IV	IV
Pollution degree	3	3

Rated insulation voltage	1000V AC	1000V AC
Rated Impulse Withstand Voltage	12 KV	12 KV
Mechanical Impacts	IK 10	IK 10
Rated current at 35deg.C	BBT-1: 2000A BBT-2: 1250 A BBT-3: 1250A	BBT-1: 2000A BBT-2: 1250 A BBT-3: 1250A
Short circuit capacity (6-Cycle)	To be quoted by the bidder	BBT 1: 2000A: Peak 176kA BBT 2: 1250A: Peak 132kA BBT 3: 1250A: Peak 132kA
Rated short time with-stand Current (KA) (t= 1 sec); phase	BBT-1: 80KA or above BBT-2: 60KA or above BBT-3: 60KA or above	BBT-1: 80KA BBT-2: 60KA BBT-3: 60KA
Rated Peak Withstand Current (KA) (t= 1 sec); phase	BBT-1: 176KA or above BBT-2: 132KA or above BBT-3: 132KA or above	BBT-1: 176KA BBT-2: 132KA BBT-3: 132KA
Rated Power Loss at 35 °C (w/m)	To be quoted by the bidder	BBT-1: 383.3 w/m BBT-2: 264.8 w/m BBT-3: 264.8 w/m
Busbar materials	Copper shall be silver plated and insulated	Copper will be silver plated and insulated
Insulation	Epoxy insulated/Mylar insulated Class-B, 130deg.C (no other insulating material will be accepted)	Epoxy insulated/Mylar insulated Class-B, 130deg.C
Special features	Single bolt clamping & sandwich principle	Single bolt clamping & sandwich principle
Enclosure	Aluminum enclosure	Aluminum enclosure
Size		
BBT-1 Imported Type Tested Assembly (TTA) Copper 2000A TP+N+PE busbar trunking system as per technical specification with all necessary bends, expansion units, transformer connection unit, distribution board connection units, fixing brackets etc. for connecting the Transformer to LT panel	Busbar cross section (Sq.mm) & model Mentioned by bidder	Model: KXC Size(Sq.mm): L1,L2,L3,N: 750 PE: 375 Aluminum enclosure: 2128 Conductor dimension(mm x mm): 6x125



EAE Elektrik Asansör End.
İnşaat Sanayi ve Ticaret A.Ş.
İst. Tic. Sic. Mük. No: 121069
Mersis No: 323 004 2973
Mersis No: 0323004297300014
Kep. mail: eaelektrik@kep.tr
Kep. hes. no: 290773602
Akçaburgaz Mahallesi, 3114. Sokak No: 10
Esenyurt 34522 İSTANBUL
T: 0 (212) 866 20 00
F: 0 (212) 866 24 20
www.eae.com.tr

BBT-2 Imported Type Tested Assembly (TTA) Copper 1250A TP+N+PE busbar trunking system as per technical specification with all necessary bends, expansion units, distribution board connection units, fixing brackets etc.	Busbar cross section (Sq.mm) & model Mentioned by bidder	Model: KXC Size(Sq.mm): L1,L2,L3,N: 420 PE: 210 Aluminum enclosure: 1842 Conductor dimension(mm x mm): 6x70
BBT-3 Imported Type Tested Assembly (TTA) Copper 1250A TP+N+PE busbar trunking system as per technical specification with all necessary bends, expansion units, distribution board connection units, fixing brackets etc.	Busbar cross section (Sq.mm) & model Mentioned by bidder	Model: KXC Size(Sq.mm): L1,L2,L3,N: 420 PE: 210 Aluminum enclosure: 1842 Conductor dimension(mm x mm): 6x70

Signature with Seal (Tenderer)

Signature with Seal (Manufacturer/Assembler)

EAE ELEKTRİK ASANSÖR
İND. İNŞAAT SAN. VE TİC. A.Ş.
Akçaburgaz Mah. 3114. Sokak No: 10 Etiler Kat: 10
İst. Tic. Sic. Mük. No: 121069 • Mersis No: 323 004 2973
www.eae.com.tr • Kep. Hes. No: 290773602
Kep. Mail: eaelektrik@kep.tr Mersis No: 0323004297300014

Cenk AYDEMİR
Export Area Manager / Export Department
Busbar Systems and Accessories