

Re: Breaker arrangement

Md. Shahriar Tuhin <aakash.tuhin@gmail.com>

Sat 6/5/2021 1:12 PM

To: A. N. M. Nasimunnabi <nasimunnabi@shaktibd.com>

Cc: engkochi007@gmail.com <engkochi007@gmail.com>; sukriti@akashgroup-bd.com <sukriti@akashgroup-bd.com>; zahid.96.369@gmail.com <zahid.96.369@gmail.com>

The amount of additional work is accepted, please go ahead.

Thanking you,

Md. Shahriar Tuhin
Electrical Engineer
Aakash Developments Ltd.
Contact:01844-050974

On Mon, May 31, 2021 at 5:43 PM A. N. M. Nasimunnabi <nasimunnabi@shaktibd.com> wrote:

Dear Tuhin Bhai,

Please note that, to carry-out the said work, you will be charged Tk. 15,000/- in addition to actual work-order value. Kindly confirm.

Thanks,

A N M Nasimunnabi | SHAKTI ENGINEERING LTD. | Senior Manager, Sales | Factory: Kudabo, Mirer Bazar, Pubail, Gazipur | Head Office: Plot 1/B, Road 90, Gulshan 2, Dhaka 1212, Bangladesh | p: +880 2 5881 1858, 2222 91442 | f: +880 2 5881 5160 | m: +88 01811 412336 | e: nasimunnabi@shaktibd.com | w: www.shaktibd.com

 please consider the environment before printing this email.

From: Md. Shahriar Tuhin <aakash.tuhin@gmail.com>
Sent: Monday, May 31, 2021 5:32 PM
To: A. N. M. Nasimunnabi <nasimunnabi@shaktibd.com>
Subject: Breaker arrangement

Dear Nasim Bhai,

Please arrange to install a 400 A TP MCCB (ABB) in place of 63A TP MCCB, if not feasible please consider to use space of both 63A TP MCCB and 32 A TP MCCB for this arrangement.

Please note that, you should provide link busbar for this 400A TP MCCB, but breaker will be installed by us later on at the site.

Thanks for your kind cooperation

Regard,

Md. Shahriar Tuhin
Electrical Engineer
Aakash Developments Ltd.
Contact:01844-050974