

M. AHMED TEA & LANDS COMPANY LIMITED

Head Office :

Dargamohalla, P.O. Box-14
Sylhet – 3100, Bangladesh
Phone : 0821-716552, 0821-718815
Fax : 880-821-715200
E-mail : m.ahmedgroup@gmail.com

Gardens :

Chandbagh T.E.
Ameenabad T.E.
Habibnagar T.E.
Khan T.E.
Lallakhal T.E.
Afifanagar T.E.

Mr. Reajul Alam
Manager – National & Strategic Sales
Cross World Power Ltd.
Plot 1/B, Road 90
Gulshan 2
Dhaka 1212

21.06.2021

Work order for supply, installation and commissioning of 30kVa TEMPEST brand DG Set at Head Office, Sylhet.

Dear Sir,

As per your quotation Ref CWPL-AM/1014/21-R03F dated 21 June 2021, we are pleased to issue you a work order for the supply, installation and commissioning of TEMPEST brand 30kVA (Prime) Diesel generator, as per the following specifications, for a total price of Tk. 7,90,000/- (Taka Seven Lac Ninety Thousand Only).

SL #	Product Name	Unit	Price (BDT)	Qty.	Total Price(BDT)
1)	TEMPEST Brand 30 KVA (Prime) Rating Diesel Generator with Perkins engine and Stamford alternator With Local Canopy & First Filling Lube oil, Coolant & Battery Acid	Set	790,000.00	1.00	790,000.00
	BRAND	: Tempest			
	ENGINE	: Perkins, UK			
	ALTERNATOR	: Stamford			
	CONTROL MODULE	: Deepsea, UK			
	PORT OF SHIPMENT	: Felixstowe port, UK			
	AVAILABILITY	: 5 to 15 days from ready stock subject to availability			

Total Price (Ready Stock) in BDT 790,000.00

GRAND TOTAL (Excluding VAT & AIT) in BDT 790,000.00

The supply of installation material during installation and commissioning shall be arranged by you, as per specifications below. Materials shall be paid in advance before delivery.

CROSS WORLD POWER LIMITED BOQ OF 30 KVA GENERATOR CLIENT - SAJIB CHOWDHURY			ADDRESS- SYLHET		DATE- 10/06/2021			
GEN MODEL-		ENGINE MODEL-		ALTERNATOR MODEL-				
ELECTRICAL INSTALLATIONS								
SL NO	JOB DESCRIPTION	TECHNICAL DETAILS/ BRAND	SCOPE OF SUPPLY	UOM	QTY	UNIT RATE	TOTAL RATE	REMARKS
1	Electrical System:							
1.1		4X1C-16 rm NYY DG To ATS		Meter	24	292	7,114	
1.2	Power Cable (35 °C Ambient on air)	4X1C-16 rm NYY Mains To ATS		Meter	N/A	-	-	Existing
1.3		4X1C-16 rm NYY ATS to Load	Client	Meter	N/A	-	-	
1.4	Power Cable Laying	4X1C-16rm		Meter	24	69	1,693	
1.5	Power Cable Lugs	16 rm , Material -Copper , Surface-Electro Tinned		Pcs	49	13	631	
1.6	Control cable For Sensing	4 X 1.2 rm (40/0.19 mm)Flexible Cable		Meter	25	106	2,647	
1.7	PVC Flexible pipe	2.5"Ø		Meter	25	112	2,794	
1.8	Saddle for Flexible pipe	2.5" Ø Local		Pcs	30	9	282	
1.9	Royal Plug & Screw	1.5" length		Pack	2	201	402	
1.10	PVC Tape	Adhesive Tape 04 color (Red/Yellow/Black/Blue)		Pcs	4	34	136	
1.11	Royal Bolt	10 no.		Pcs	10	12	118	
1.12	Cable Tie	L - 6"/8 "		Pack	2	162	325	
2	Generator Earthing :					-	-	
2.1	Earthing Boring	1 Nos, 100 feet boring		Job	1	8,514	8,514	
	GI Pipe (Boring)	38.1mm Dia		Meter	7	568	3,978	
2.2	Earthing Copper Lead (Boring)	4 SWG		Meter	32	308	9,867	
	Earthing Copper Lead (Termination)	2 SWG		feet	3	308	940	
2.3	Earthing Block	LXWXD - 200mm X 30mm X 5mm with connection facility, isolator, royal bolt etc		Pc	1	2,476	2,476	
2.4	Earthing Cable	1 X 10 rm BYA (Green) from Earthing Copper bar to gen & equipment		Meter	12	161	1,969	
2.5	Earthing Cable Lugs	10 rm , Material -Copper , Surface-Electro Tinned		Pcs	4	9	38	
3	Exhaust System:					-	-	
3.1	Exhaust Silencer straight Pipe	MS Pipe bore 3" ,thickness 3-4mm	Client	Meter	0	-	-	Client will provide
3.2	Exhaust Bends /Elbow	Long radius 90 deg L bow		Pcs	1	852	852	
3.3	Exhaust Flange	Threaded 3"dia MS Flange		Pcs	2	696	1,393	
	Reducer	2"-3"		Nos	1	542	542	
3.4	Exhaust Heat Insulation	Insulation Of Pipe with Rockwool/Glasswool (25.4mm min thickness) along with 26SWG Aluminium sheet cladding		Job	1	1,601	1,601	
3.5	Exhasut Fitting	All bracket , support must be made with MS angle 50X50X 4, 5 & 6 MM		Job	1	774	774	
04	Cooling System:					-	-	
4.1	Radiator Ducting	WXH - , L - As per layout with 22 SWG MS sheet,Angle bar, flat bar support ,Canvas cloth etc		Sq-ft	N/A	-	-	Infront of the canopy
5	Commissioning Material:						-	
5.1	Radiator coolant	Havoline Premix Coolant		Liter	10	160		Included in the Genset Offer
5.3	Lube oil	SAE 15 W 40		Liter	10	420		
5.4	Battery electrolyte	Specific gravity 1250		Liter	10	90		
06	DG On site delivery:						-	
6.1	* Loading /Unloading/Lifting	Generator weight-954 Kg with Comm. Materials	CWPL	Job	1		-	
07	Civil works:						-	
7.1	Generator foundation	Dimension L X W -7'-6" "X5'-6"Depth D: 6"	CLIENT	Job	1		-	
						Total Taka (Excluding VAT & Tax)	49,087	
						Discount	3,087	
						Total Taka (Excluding VAT & Tax)	46,000	
Note: All Types of Civil work will be done by client.								

You are advised to complete the supply, installation and commissioning of the generator at our Head Office in Sylhet as soon as possible. As per your commitment, 90% payment shall be paid in advance, while the remaining 10% shall be paid with a 7 days post-dated cheque before delivery.

We are taking necessary action to make payment for the above order after we receive your confirmation. Thank you.

Kind Regards,

Sajid Choudhury
Director