

Check list for Acceptance of New DG

Site ID: **DHXX-1996**
 O&M Office: **Jamal Pur**
 FLM Office: **Jamal Pur**
 Power Status: **CP + DG**
 BTS Type: **Indoor**

Date: **13-04-21**
 Thana: **Malandho**
 District: **Jamal Pur**
 Address: **Maloneho bazar, Malandho Jamal Pur**

Job Category (✓) **✓** **DG Installation**

DG Capacity: **20KVA**

DG Brand: **Tempest** Canopy: Standard **Super sound proof**

Running Hour: **00H**

Item Description	Manufacturer	Model	Serial Number	Status Check (OK / Not OK)	Readings / Observations / Comments
Engine	Perkins	GV5120	U971673E	OK	
Starter Battery (Brand)	Yuasa			OK	
Battery Capacity (No. of plate & AH)	17P	70AH			
Battery Cable	N/A	N/A	N/A	OK	
DG Radiator	N/A	N/A	N/A	OK	
Engine temperature (After 1 hour load test)	N/A	N/A	N/A	OK	
Lube oil pressure	N/A	N/A	N/A	OK	
Lube oil Level	N/A	N/A	N/A	OK	
Engine RPM	N/A	N/A	N/A	OK	
Self Starter	N/A	N/A	N/A	OK	
DG Controller (Need to mention Brand, Model & SL no.)				OK	
Fuel Pump	N/A	N/A	N/A	OK	
Water Pump	N/A	N/A	N/A	OK	
DG Auto Charger	N/A	N/A	N/A	OK	
Alternator				OK	
Charging Alternator	N/A	N/A	N/A	OK	
AMF/ATS				OK	
ATS (Existing)				—	under Rating MC (32A)
DG servicing	N/A	N/A	N/A	OK	
VDT	N/A	N/A	N/A	OK	
Generator sound level 60 dBA @ 1 meter (running condition with load)	N/A	N/A	N/A	OK	
Surrounding space is available for regular maintenance	N/A	N/A	N/A	OK	
DG room air circulation	N/A	N/A	N/A	OK	
Generator Grounding result $\leq 1\Omega$	N/A	N/A	N/A	OK	
During depth (Meter) for required Grounding result (Need to mention the meter)	N/A	N/A	N/A	OK	
Generator Grounding pit must be concret slab & square size brick wall with additional multi hole copper bar.	N/A	N/A	N/A	OK	
Generator Neutral to grounding voltage, (it must be measure without connection of grounding in DG body & without twisted the DG neutral with CP neutral)	N/A	N/A	N/A	OK	
DG exhaust system (silencer pipe must need to be extend till outside the room)	N/A	N/A	N/A	OK	
DG cleaning	N/A	N/A	N/A	OK	

List of pending issue to be rectified

- 1)
- 2)
- 3)
- 4)
- 5)

General Remarks

DG install done, DG run and check with load.

Vendor Concern:

FLM Concern:

BL O&M Concern:

Company Name: **cross world Ltd.**
 Representative Name: **Ahasan Habib Rakib.**
 Date: **24-04-21**
 Mobile: **01708-983820**

FLM Office :
 FLM POC Name:
 Date:
 FLM POC Mobile:

Name: **md. Jonnal kabe**
 Designation: **Engineer**
 Date: **24-04-2021**
 Mobile: **01902559982**

Check list for Acceptance of Shifted Old DG

Site ID	DHXX-1996.
O&M Office	Jamalpur.
FLM Office	Jamalpur.
Previous Power Status	CP+DG.
BTS Type	Indoor.

Thana	Malandho,
District	Jamalpur,
Address	Malandho bazar, Malandho, Jamalpur

Shutdown DG Brand and capacity	Sinoma, 10kVA.
Shutdown DG functional status before Turn on (Good/Partial Faulty/Major Faulty)	Partial faulty.
DG Room Available (yes/No)	Yes
Fuel Tank Capacity	2000 ltr.
Materials installed/replaced for DG Turn On	—
DG Turn On Status	
Actual Date of Turn On	
DG RH during Turn On	
Current Fuel Stock	
Remarks	

[illegible]

DG Functional Status	Ok	Not Ok	NA	Remarks
Genset On Alarm Integration Status	OK			
DG Battery Status	OK			
New Battery Serial no				
DG Controller status	OK			
DG Radiator status	OK			
Self Starter status	OK			
Charging Alternator staus	OK			
Fuel Pump Status	OK			
Water Pump staus	OK			
DG Auto Charger status	OK			
ATS Status	OK			
DG servicing status	OK			
DG RH during servicing				
VDT Status	OK			

List of pending issue to be rectified	1)	
	2)	
	3)	
	4)	
	5)	
	6)	

Wakim

Power Vendor Concern

Power Vendor Name: Crossworld Ltd.
Vendor POC Name: Ahasan Habib Rakib.
Vendor POC Mobile: 01708-483820.

O&M or FLM Concern

BL O&M or FLM Office :
O&M/FLM POC Name: *md. Jannul Kayer.*
O&M/FLM POC Mobile: *01902 539982*

Supporting Photographs			
Site ID	DHKX-1006	Date: 13-04-21	
O&M Office	Jamalpur	Thana: Malandho	
FLM Office	Jamalpur	District: Jamalpur	
Power Status	EP + DG	Address: Malanchobatar, Malandho, Jamalpur	
BTS Type	Indoor		
Job Category (V)	LDG Installation	DG Capacity	20kVA
DC Brand: Tempest	Canopy: Super Sound Proop.	Running Hour:	00H.
Before Photographs			
3 Minimum Photo from different angle need to insert for each			
After Photographs			
3 Minimum Photo from different angle need to insert for each			
General Remarks			
1. ATS MC under rated (32A) 2. MC channel very small. 3. Neutral connection coming busbar need to be separated with MC port.			
Vendor Concern Company Name: GROSS WORLD LTD. Representative Name: Ahasan Habib Rakib Date: 24-04-21 Mobile: 01708485800		FLM Concern FLM Office: FLM POC Name: Date: FLM POC Mobile:	
		BL O&M Concern Name: Md. Faruk Hasan Designation: Engineer Date: 24-04-2021 Mobile: 01702559982	

CROSS WORLD POWER LTD.

Cross-world

Ensuring Power Since 1983

Delivery Challan

From Cross World Power Limited. House # 1/B, Road # 90, Gulshan-2, Dhaka-1213. Tell: 8811858, 8816528 Fax: 8816205	To Banglalink Digital Communications LTD. Tiger's Den, House-04, (SW) Bir Uttam Mir Shawkat Sharak, Gulshan-1, Dhaka-1212, Bangladesh. Mr. Imrul Kayes, 01902559982,01712456264
--	---

Sales Person: Md. Moshir Rahman	Contact No: 01755 514 703
---------------------------------	---------------------------

Site Address: DHK_X1996, Site Address: MD.Abdul Karim,Malanha,Bazar,Upazila:Melandaha,Jamalpur.

Challan No: CWPL-DO/0090/2 Date of Delivery: Apr 12, 2021	Your Order No: CWPL-AM/0212/21-003 Date: Jan 13, 2021
--	--

Serial No.	Description of Goods	Unit	Quantity	Remarks
01	Supply of Auto 20KVADiesel Generator Brand: Tempest Engine: Perkins Alternator: Stamford	Set	01	All materials are in good condition
02	Supply of Battery	Set	01	
03	Supply of Battery Cable (2 Nos.)	Set	01	
04	Supply of Silencer Box	Set	01	
05	Supply of Bellows	Set	01	
06	Supply of Foreign Canopy for 20 KVA Genset	Set	01	
07	Supply of ocal Auto Transfer Switch (ATS) for 20 KVA Genset	Set	01	

Prepared By

Signature

Name: Md. Sonel Ahmed
Designation: Executive (Store)
Office ID: 1403
Contact No: 01755514745

Delivery By

Signature

Name: AKM Saiful Bashar
Designation: Sr. Executive (Logistics)
Office ID: 1020
Contact No: 01755514742

Received by Customer

Signature

Name: Md. Rabiul Islam (Xousuf)
Designation: Re.
Office ID:
Contact No: 01976016883

CWG-QM/FORM-0033

Revision No.:00

Page 1 of 1

CROSS WORLD POWER LTD

Delivery Challan

To
Banglalink Digital Communications Limited

Site Address : DHK_X1996,
Karim, Malancha, Bazar, Upazila: Melandaha, J
amalpur

Challan No : 5601
Date : 12-Apr-21
Offer Ref. : CWPL-AM/0212/21-00:

SL	Code	Part No	Product Name	Unit	RecQty
1	4906	4X1.2 RM	Control Cable 4X1.2 rm	Mtr	20.00
2	2970	1.5 Inch.	Flexible Pipe PVC	Mete	20.00
3	3610	1.5 Inch.	saddle	Pc	10.00
4	8016		royal plug and Screw	Pack	1.00
5	6827	10rm.	Cable Lugs 10rm.	Pc	12.00
6	2951	R,Y,B,B, G	PVC Tape	Pcs	2.00
7	9186	10 mm	Royal Bolt 10 mm	Pc	10.00
8	2994	8 Inch.	Cable tie 8 Inch.	Pack	1.00
9	6542	3200 Amps.	Mechanical Inter Lock.	Pc	1.00
10	6134	1" Dia.	PVC Clamp 1"	Pc	5.00
11	9303	8 Pin	AC Relay with base 230 Volt (8 Pin)	Pc	1.00
12	2971		CAT 6 Cable	Mete	20.00
13	5177	3" Dia	Silencer Pipe 3" Dia	Mtr	4.00
14	6866	3 inch	Exhaust Bend -3-inc	Pc	2.00
15	3728	"3/4""	Fuel pipe	Mtr	10.00
16	8017	3."-2" Dia	Reducer 3."-2" Dia	Pc	1.00
17	10413		Socket 3" Dia	Pc	1.00
18	6374		Exhaust Heat Insulation.	Job	1.00
19	8470		Exhaust Fitting.	Job	1.00
20	8763		Earthing Boring	Job	3.00
21	9270	4 SWG	Earthing Copper Lead	Mtr	29.00
22	3894	1X10 RM	Earthing Cable 1X10 RM	Mtr	17.00
23	4191	35 RM	Cable Lugs 35 RM	Pc	3.00
24	10355	(600x600x600)mm	Earthing Pit	Job	1.00
25	4694		Earthing Block.	Pc	1.00
26	3388	Premixed	Coolant Havoline	Ltr	10.00
27	8571	Petronus, 15w4o	Lube Oil	Ltr.	8.00

Delivery By :

Signature :

Name :

ID / Mobile :

Date :

Receive the Material(s) in good order & condition

Signature :

Name

ID / Mobile

Date

Ahasan Habib Rakib
01708983890
12/04/21

Site Address : DHK_X1996,
Karim, Malancha, Bazar, Upazila: Melandaha, J
amalpur

Challan No : 5601
Date : 12-Apr-21
Offer Ref. : CWPL-AM/0212/21-00:

SL	Code	Part No	Product Name	Unit	RecQty
28	3707		Battery Acid	Ltr	10.00
				Total :	205.00

Delivery By :

Signature :

Name :

ID / Mobile :

Date :



Receive the Material(s) in good order & condition

Signature :

Name :

ID / Mobile :

Date :


: Alhasan Habib Rakib,
: 01708-483820
: 13-04-21,