

Check list for Acceptance of New DG

Site ID	DHK-X0726
O&M Office	
FLM Office	
Power Status	
BTS Type	Huawei

Date:	26-04-2021
Thana:	Ashulia-Thana
District:	SAVNA
Address:	Baliyodra Bar2201

Job Category (✓)	DG Installation
------------------	-----------------

DG Capacity	30kVA
-------------	-------

DG Brand: Tempest	Canopy: Standard / Super sound proof
-------------------	--------------------------------------

Running Hour:	2H.
---------------	-----

Item Description	Manufacturer	Model	Serial Number	Status Check (OK / Not OK)	Readings / Observations / Comments
Engine			DJ 2200306373		OK
Starter Battery (Brand)			DE		OK
Battery Capacity (No. of plate & AH)			80AH		OK
Battery Cable	N/A	N/A	N/A		OK
DG Radiator	N/A	N/A	N/A		OK
Engine temperature (After 1 hour load test)	N/A	N/A	N/A		OK
Lube oil pressure	N/A	N/A	N/A		4.8
Lube oil Level	N/A	N/A	N/A		
Engine RPM	N/A	N/A	N/A		1530 RPM
Self Starter	N/A	N/A	N/A		
DG Controller (Need to mention Brand, Model & SL no.)	UK	7120MCE-1			
Fuel Pump	N/A	N/A	N/A		OK
Water Pump	N/A	N/A	N/A		OK
DG Auto Charger	N/A	N/A	N/A		OK
Alternator			BPLS03433		OK
Charging Alternator	N/A	N/A	N/A		OK
AMF/ATS					OK
ATS (Existing)					OK
DG servicing	N/A	N/A	N/A		OK
VDT	N/A	N/A	N/A		OK
Generator sound level 60 dBA @ 1 meter (running condition with load)	N/A	N/A	N/A		NA
Surrounding space is available for regular maintenance	N/A	N/A	N/A		OK
DG room air circulation	N/A	N/A	N/A		OK
Generator Grounding result $\leq 1\Omega$	N/A	N/A	N/A		OK
Boring depth (Meter) for required Grounding result (Need to mention the meter)	N/A	N/A	N/A		OK
Generator Grounding pit must be concret slab & square size brick wall with additional multi hole copper bar.	N/A	N/A	N/A		OK
Generator Neutral to grounding voltage.(it must be measure without connection of grounding in DG body & without twisted the DG neutral with CP neutral)	N/A	N/A	N/A		OK
DG exhaust system (silencer pipe must need to be extend till outside the room)	N/A	N/A	N/A		OK
DG cleaning	N/A	N/A	N/A		OK

List of pending issue to be rectified	1)
	2)
	3)
	4)
	5)

General Remarks

DG installation work done Generator Run with Load.
Test OK & Grounded on Load Alarm Check & Auto Check done.

EM

Vendor Concern:	CWPL
Company Name:	Cross-world Power Ltd.
Representative Name:	MD. ABU Hossain/Masum
Date:	26-04-2021
Mobile:	01755514863

FLM Concern:	
FLM Office:	
FLM POC Name:	
Date:	
FLM POC Mobile:	

BL O&M Concern:	
Name:	Eusan
Designation:	BSS officer
Date:	26-4-21
Mobile:	01726100929

Supporting Photographs			
Site ID	DhK XI-0726	Date:	26-04-2021
O&M Office		Thana:	Ashmuni
FLM Office		District:	
Power Status		Address:	Buliyadra Bazzar
BTS Type			
Job Category (V)	DG Installation	DG Capacity	30KVA
DG Brand	Tempest	Running Hour:	114
Before Photographs			
3 Minimum Photo from different angle need to insert for each			
After Photographs			
3 Minimum Photo from different angle need to insert for each			
General Remarks			
Vendor Concern	FLM Concern	BL O&M Concern	
Company Name: Express-World Power Ltd.	FLM Office:	Name: Eman	
Representative Name: Md Abu Hassam/Masum	FLM POC Name:	Designation: BSS Officer	
Date:	Date:	Date: 26-4-21	
Mobile: 01735514863	FLM POC Mobile:	Mobile: 01916100927	

CROSS WORLD POWER LTD.



Delivery Challan

From Cross World Power Limited. House # 06, Road # 92, Gulshan-2, Dhaka-1213. Tell: 8811858, 8816528 Fax: 8816205	To Banglalink Digital Communications LTD. Tiger's Den, House-04, (SW) Bir Uttam Mir Shawkat Sharak, Gulshan-1, Dhaka-1212, Bangladesh. Mr. Delowar, 01911310752
---	---

Sales Person: Md. Moshir Rahman	Contact No: 01755 514 703
---------------------------------	---------------------------

Site Address: DHK_X0726, Latif Super Market, Balivadra bazar, Dhamsona, Savar, Dhaka.

Challan No: CWPL-DO/0121/21 Date of Delivery: Apr 22, 2021	Your Order No: CWPL-AM/0509/21-002 Date: Jan 18, 2021
---	--

Serial No.	Description of Goods	Unit	Quantity	Remarks
✓ 01	Supply of Auto 30KVADiesel Generator Brand: Tempest Engine: Perkins Alternator: Stamford	Set	01	All materials are in good condition
✓ 02	Supply of Battery	Set	01	
✓ 03	Supply of Battery Cable (2 Nos.)	Set	01	
✓ 04	Supply of Silencer Box	Set	01	
✓ 05	Supply of Bellov s	Set	01	
✓ 06	Supply of Foreign Canopy for 30 KVA Genset	Set	01	
✓ 07	Supply of ocal Auto Transfer Switch (ATS) for 30 KVA Genset	Set	01	

Prepared By

Signature

Name: Md. Sohail Ahmed
Designation: Executive (Store)
Office ID: 1403
Contact No: 01755514745

Delivery By

Signature

Name: AKM Saiful Bashar
Designation: Sr. Executive (Logistics)
Office ID: 1020
Contact No: 01755514742

Received by Customer

Signature

Name: Md Ensan
Designation: BSS ofsr
Office ID: 20268
Contact No: 01916200929

CWG-QM/FORM-0033

Revision No.:00

Page 1 of 1

CROSS WORLD POWER LTD

Delivery Challan

To
Banglalink Digital Communications Limited

Site Address : Site ID DHK_X0726, Latif Super Market,
Balivadra bazar, Dhamsona, Savar, Dhaka.

Challan No : 5606
Date : 22-Apr-21
Offer Ref. : CWPL-AM/0509/21-001

SL	Code	Part No	Product Name	Unit	RecQty
✓1	4906	4X1.2 RM	Control Cable 4X1.2 rm	Mtr	20.00
✓2	2970	1.5 Inch.	Flexible Pipe PVC	Mete	20.00
✓3	3610	1.5 Inch.	saddle	Pc	10.00
✓4	8016		royal plug and Screw	Pack	1.00
✓5	6827	10rm.	Cable Lugs 10rm.	Pc	12.00
✓6	2951	R,Y,B,B, G	PVC Tape	Pcs	2.00
✓7	9186	10 mm	Royal Bolt 10 mm	Pc	10.00
✓8	2994	8 Inch.	Cable tie 8 Inch.	Pack	1.00
9	6542	60 3200 Amps.	Mechanical Inter Lock.	Pc	1.00
✓10	6134	1" Dia.	PVC Clamp 1"	Pc	5.00
✓11	9303	8 Pin	AC Relay with base 230 Volt (8 Pin)	Pc	1.00
✓12	2971		CAT 6 Cable	Mete	20.00
13	5177	3" Dia	Silencer Pipe 3" Dia	Mtr	4.00 2.00
✓14	6866	3 inch	Exhaust Bend -3-inc	Pc	2.00 1.00
✓15	3728	"3/4" "	Fuel pipe	Mtr	10.00
✓16	8017	3."-2" Dia	Reducer 3."-2" Dia	Pc	1.00
✓17	10413		Socket 3" Dia	Pc	1.00
✓18	6374		Exhaust Heat Insulation.	Job	1.00
✓19	8470		Exhaust Fitting.	Job	1.00
✓20	8763		Earthing Boring	Job	3.00
✓21	9270	4 SWG	Earthing Copper Lead	Mtr	29.00
✓22	3894	1X10 RM	Earthing Cable 1X10 RM	Mtr	17.00
✓23	4191	35 RM	Cable Lugs 35 RM	Pc	3.00
✓24	10355	(600x600x600)mm	Earthing Pit	Job	1.00
✓25	4694		Earthing Block.	Pc	1.00
✓26	3388	Premixed	Coolant Havoline	Ltr	10.00
✓27	8571	Petronus, 15w4o	Lube Oil	Ltr.	8.00

Delivery By :

Receive the Material(s) in good order & condition

Signature

Name

ID / Mobile

Date

Signature

Name

ID / Mobile

Date

[Signature]

Md. Enson ab

01916100927

26-4-21

Address : Site ID DHK_X0726, Latif Super Market,
Balivadra bazar, Dhamsona, Savar, Dhaka.

Challan No : 5606
Date : 22-Apr-21
Offer Ref. : CWPL-AM/0509/21-001

SL	Code	Part No	Product Name	Unit	RecQty
✓ 28	3707		Battery Acid	Ltr	10.00
29	1		PVC Rope 2" 20ft		
				Total :	205.00

Delivery By : 

Receive the Material(s) in good order & condition

Signature : 
Name : 
ID / Mobile : 
Date : 

Signature : 
Name : Md Ensanul
ID / Mobile : 01916100922
Date : 22-4-21

Cross-world

DELIVERY CHALLAN

To

Bangladesh
Dak X-726.

CROSS WORLD LIMITED

House # 1/B, Road # 90
Gulshan-2, Dhaka-1212, Bangladesh
Tel: (880 2) 8811858, 8816528.
Fax: (880 2) 8816205.

Challan No:

Date:

26.04.21

Your Order No: As per our quotation.

SL NO:	DESCRIPTION OF GOODS	UNIT	QUANTITY
01.	Power Cable . 16 km	mtr.	41.00
2.	Teleponic	mtr.	100 mtr.

Delivered by:

CWL

Received the stores in good order & condition

Signature

Name

ID/Mobile No

Signature

Name

ID/Mobile No

Signature

Name

ID/Mobile No

Signature

Name

ID/Mobile No

Prepared by : Md Tiptu Sultan
Mobile No : 01755514823